

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 13-51-2136187
Name of Facility: Andrea Castillo Preparatory Academy K-8
Address: 10201 NW 78TH Street
City, Zip: Miami 33178

Correct By: None
Re-Inspection Date: None

Type: Public Schools
Owner: Public School, Miami Dade County - Andrea Castillo Preparatory Acad
Person In Charge: Andrea Castillo Preparatory Academy K-8 Phone: (786) 275-0464
PIC Email: acosta@dadeschools.net

Inspection Information

Purpose: Routine
Inspection Date: 9/7/2022

Begin Time: 01:25 PM
End Time: 02:25 PM

Additional Information

FEMALES 104
MALES 119

CENSUS 223

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	IN 15. Shower Facilities	NA 23. Sanitizers
IN 4. Construction	IN 16. Showers Water Temperatures	NA 24. Changing Station & Mats
IN 5. Maintenance & Repair	WATER SUPPLY	NA 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	NA 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	NA 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	NA 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	NA 29. Other

Marking Key: **IN** = the act or item was observed to meet standards; **OUT** = the act or item was observed not to meet standards; **NO** = the act or item was not observed to be occurring at the time of inspection; **NA** = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Inspection done during COVID-19.
Brand new school.
Adolfo Costa (Principal), assisted with inspection.

Email Address(es): acosta@dadeschools.net

Violations Comments

No Violation Comments Available

Inspection Conducted By: Alberto Reyes (032763)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name:
Date: 9/7/2022

Inspector Signature:

Handwritten signature of Alberto Reyes.

Client Signature:

Handwritten signature of Andrea Castillo.